

6390 Philips Highway Jacksonville, FL 32216 Phone (904) 737-7144

SPECIFICATION DATA SHEET

MODEL No. 3212-DS2

CONICAL TAKEOFF FOR ROUND TRUNK DUCT WITH MANUAL VOLUME DAMPER AND STANDOFF

Date: 09.

Date: 09/11/13 Drawn by: M.D.C.

DIMENSIONAL DATA

SIZES AVAILABLE: 4" THROUGH 20"

CONICAL CONNECTION HOLE TO TRUNK DUCT IS APPROXIMATELY 2" GREATER THAN BRANCH DUCT DIMENSION.

5 3/8" LONG COLLAR.

FABRICATION DATA

MATERIAL:

FABRICATED FROM HOT DIPPED GALVANIZED STEEL SHEETS PER ASTM-A653 CS TYPE B.

GAUGES:

4" THROUGH 8" = 28 GAUGE

9" THROUGH 14" = 26 GAUGE

16" THROUGH 20" = 24 GAUGE

FEATURES


CONTINUOUS WELD LONGITUDINAL SEAM FOR NO AIR LEAKAGE AT 2" W.G. STATIC PRESSURE.

1" WIDE FLANGE WITH GASKET AND PRE-DRILLED SCREW HOLES FOR EASE OF INSTALLATION.

ALL SIZES: 3/8" CONTINUOUS ROD DAMPER AXIS WITH LOCKING REGUALTOR, NYLON GROMMETS INSTALLED AT THE COLLAR PENETRATIONS.

2" DAMPER HANDLE STANDOFF.

TAKEOFF CONTOURED TO MATCH RADIUS OF TRUNK DUCT.



SPECIAL NOTES

RECOMMENDED INSTALLATION: DAMPER AXIS PARALLEL TO AIR FLOW.

MADE TO MEET S.M.A.C.N.A. GAUGE STANDARDS. MAXIMUM 2" W.G. STATIC PRESSUDE SCHEDULE.

(S.M.A.C.N.A. HVAC DUCT CONSTRUCTION STANDARDS, SECOND EDITION-1995)

NOTE BRANCH DUCT DIMENSION WHEN ORDERING.